

CITY OF HOUGHTON
2010 WATER QUALITY CONSUMER CONFIDENCE REPORT

Regulation background:

Following new federal regulations, the State of Michigan in 1998 enacted a requirement that public water suppliers must now issue annual Consumer Confidence Reports (CCR) on water systems. Therefore, this report is issued to provide City of Houghton Water Customers with information on drinking water.

Summary of City Water System:

The water is piped from the Water Treatment Plant to four tanks; one that holds 440,000 gallons, two that hold 750,000 gallons, and one high-elevation tank in that holds 275,000 gallons. The City uses about 1,100,100 gallons of water per day. The City has about 1,500 customers, of which 1,100 are single-family units. The City has about 30 miles of water distribution mains that are 4 inches to 16 inches in diameter, approximately 20 miles of service lines that are 3/4 inches to 2 inches in diameter, and approximately 275 fire hydrants. Water charges are \$3.15 per 100 cubic feet (or 748 gallons).

Portage Township purchases approximately 10,000,000 (more or less) gallons of water per year from the City of Houghton.

The City has completed a formal Wellhead Protection Plan.

Chlorine is added to the Water System to maintain a chlorine residual as a precaution for possible entry of harmful bacteria into the distribution system. The City's water supply contains high levels of iron and manganese. Soda ash and potassium permanganate are added to remove the iron and manganese from the ground water in conjunction with the filtration system that the City uses.

General Water Educational Information (as required by the EPA):

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or EPA's Web site at www.epa.gov/safewater/hfacts.html.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, spring, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and picks up substances resulting from the presence of animals or from human activity.

The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a six-tiered scale from "very-low" to "high" based primarily upon geologic sensitivity, water chemistry and contaminant sources. The susceptibility of our source is as follows: Well #1-susceptibility is moderately high, Well #2-susceptibility is moderately high, Well #3-susceptibility is moderately high.

Copies of the report may be obtained at the City of Houghton offices upon request.

Contaminants that may be present in source water before treatment include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture and residential uses.
- Radioactive contaminants, which are naturally occurring.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

City Water Quality Results:

The City of Houghton is pleased to report that with the exception of lead testing in 1999, no contaminants were detected. U.S. EPA Regulations have set the 90th percentile action level at 15 parts per billion (ppb) for lead. It should be noted that subsequent testing has revealed that the City of Houghton's water supply 90th percentile results are in compliance with limits under the regulation.

Lead Monitoring Data

Terms and Abbreviations:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as possible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which if exceeded, triggers treatment or Other requirements which a water system must follow.

PPM: Parts per million or milligrams per liter

Ppb: Parts per billion.

NA: Not applicable

ND: Not detected

Copper: <u>AL</u>	<u>MCLG</u>	<u>City/Houghton</u>	<u>Sample exceeded</u> <u>Action Level</u>	<u>Date</u>	<u>Violation</u>
1300ppb	1300ppb	ND	1 out of 20 (1320ppb)	07/01/08	No

Copper: Typical sources of contaminant - erosion of natural deposits, leaching, corrosion of household plumbing.

Lead: <u>AL</u>	<u>MCLG</u>	<u>City/Houghton</u>	<u>Sample exceeded</u> <u>Action Level</u>	<u>Date</u>	<u>Violation</u>
15ppb	0	ND	1 out of 20 (21.3ppb)	07/01/08	No

Regulated Contaminants:

	<u>MCL</u>	<u>MCLG</u>	<u>City Water</u>	<u>Date</u>	<u>Violation</u>
Arsenic	10ppb	0	ND	05/21/10	No
Mercury	2 ppb	2ppb	ND	05/21/10	No
Fluoride	4 ppb	-	ND	09/08/10	No

Arsenic: Typical source of contaminant - erosion of natural deposits.

Mercury: Typical source of contaminant - erosion of natural deposits.

Fluoride: Typical source of contaminant – erosion of natural deposits.

Inorganic Contaminants:

Sulfate ¹	<u>MCLG</u>	<u>City/Houghton</u>	<u>Range</u>	<u>Date</u>	<u>Violation</u>	
			<u>Low</u> <u>High</u>			
	N/A	7 mg/L	n/a n/a	09/07/10	No	
Nitrate	<u>MGL</u>	<u>MCGL</u>	<u>City/Houghton</u>	<u>Range</u>	<u>Date</u>	<u>Violation</u>
			<u>Low</u> <u>High</u>			
	10 mg/L	10mg/L	.8 mg/L n/a	09/07/10	No	

Sulfate - Typical source of contaminant-erosion of natural deposits.

Nitrate - Typical source of contaminant - runoff from fertilizer use; leaching from septic tanks, sewage.

¹ Sulfate is an unregulated contaminant and thus there is no MCL associated with it. Unregulated contaminant monitoring helps EPA to determine whether there is a need to regulate that contaminant.

Total Trihalomethanes: Typical source of contaminant; by-product of drinking water chlorination

<u>MCL</u>	<u>MCLG</u>	<u>CITY WATER</u>	<u>Date</u>	<u>Chlorination Violation</u>
80ppb	N/A	41 ppb	09/08/10	No

Haloacetic Acids: Typical source of contaminant; by-product of drinking water chlorination

<u>MCL</u>	<u>MCLG</u>	<u>CITY WATER</u>	<u>Date</u>	<u>Chlorination Violation</u>
60ppb	N/A	15 ppb	09/08/10	No

For More Information:

Copies of all test results are available at City Center. For more information, please contact the City Office at (906)482-1700. The City of Houghton is committed to providing the best quality water and water information to our valued customers.

Copies of test results for Portage Township may be obtained at the Portage Township Office at Box 750, Green Acres Road, Houghton, MI 49931 or by calling (906)482-4310. Portage Township is committed to providing the best quality water and water information to their valued customers.

PORTAGE TOWNSHIP
Bruce Peterson, Supervisor

CITY OF HOUGHTON
Robert Backon, Mayor
Report Mailed on 06/28/10

Scott MacInnes, City Manager

Mark Zenner, Public Works Director

CITY OF HOUGHTON
2010 WATER QUALITY CONSUMER CONFIDENCE REPORT

Report Mailed or Hand Delivered to the following on June 28, 2011:

Bill Polkinghorn, Houghton Portage Township Schools
Doreen Klingbeil, Houghton Elementary School
Guy St. Germain, Western U.P. Health Department
Doug Pascoe, MDEQ, Negaunee
Andy Niemi – MTU Facilities
MTU Health Lab (hand delivered)
Bruce Peterson, Portage Township Supervisor
Daily Mining Gazette
Kristine Bradof